

This information was generated by the HP KEYMARK database on 14 Oct 2022

[Login](#)

Summary of	HA 3-5 OS 230V / HA 5-5 OS 230V		Reg. No.	40049297
Certificate Holder				
Name	Saunier Duval Brand Group			
Address		Zip		
City		Country	Germany	
Certification Body	VDE Prüf- und Zertifizierungsinstitut GmbH			
Subtype title	HA 3-5 OS 230V / HA 5-5 OS 230V			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A			
Mass of Refrigerant	1.5 kg			
Certification Date	29.04.2021			
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018; DIN EN 14511-2:2019-07; EN 14511-2:2018; DIN EN 14511-3:2019-07; EN 14511-3:2018; DIN EN 14511-4:2019-07; EN 14511-4:2018; DIN EN 14825:2019-07; EN 14825:2018; DIN EN 12102-1:2018-02; EN 12102-1:2017			

Model: HA 3-5 OS 230V + HA 5-5 WSB

Configure model	
Model name	HA 3-5 OS 230V + HA 5-5 WSB
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.13 kW	2.73 kW
El input	0.64 kW	1.05 kW
COP	4.89	2.62

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	156 %
Prated	3.76 kW	3.31 kW
SCOP	6.41	3.98
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.76 kW	3.31 kW
COP Tj = +2°C	3.69	2.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.25 kW	2.06 kW
COP Tj = +7°C	5.81	3.36
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.70 kW	2.41 kW
COP Tj = 12°C	8.08	5.31
Cdh Tj = +12 °C	0.970	0.980

This information was generated by the HP KEYMARK database on 14 Oct 2022

Pdh Tj = Tbiv	3.76 kW	3.31 kW
COP Tj = Tbiv	3.69	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.76 kW	3.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.69	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	783 kWh	1111 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	155 %	107 %
Prated	3.91 kW	2.82 kW
SCOP	3.96	2.76
Tbiv	-13 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	2.36 kW	1.78 kW
COP Tj = -7°C	3.44	2.32
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	1.96 kW	1.70 kW
COP Tj = +2°C	4.80	3.54
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.34 kW	2.09 kW
COP Tj = +7°C	6.54	4.79
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.68 kW	2.43 kW
COP Tj = 12°C	8.00	6.07
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	2.99 kW	2.30 kW
COP Tj = Tbiv	2.80	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.22 kW	2.30 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.91 kW	2.82 kW
Annual energy consumption Qhe	2439 kWh	2517 kWh
Pdh Tj = -15°C (if TOL<-20°C)	2.22	2.30
COP Tj = -15°C (if TOL<-20°C)	2.17	1.72
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	185 %	130 %
Prated	4.00 kW	3.51 kW
SCOP	4.70	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.10 kW
COP Tj = -7°C	3.19	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.18 kW	2.04 kW
COP Tj = +2°C	4.50	3.26
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.32 kW	2.02 kW
COP Tj = +7°C	6.15	4.36
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.74 kW	2.44 kW
COP Tj = 12°C	8.42	5.86
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	3.54 kW	3.10 kW
COP Tj = Tbiv	3.19	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.24 kW	2.75 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.76 kW	0.76 kW
Annual energy consumption Qhe	1758 kWh	2177 kWh

Model: HA 3-5 OS 230V + HA 5-5 STB

Configure model	
Model name	HA 3-5 OS 230V + HA 5-5 STB
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.13 kW	2.73 kW
El input	0.64 kW	1.05 kW
COP	4.89	2.62

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	156 %
Prated	3.76 kW	3.31 kW
SCOP	6.41	3.98
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.76 kW	3.31 kW
COP Tj = +2°C	3.69	2.24
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.25 kW	2.06 kW
COP Tj = +7°C	5.81	3.36
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.70 kW	2.41 kW
COP Tj = 12°C	8.08	5.31
Cdh Tj = +12 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 14 Oct 2022

Pdh Tj = Tbiv	3.76 kW	3.31 kW
COP Tj = Tbiv	3.69	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.76 kW	3.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.69	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	783 kWh	1111 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	155 %	107 %
Prated	3.91 kW	2.82 kW
SCOP	3.96	2.76
Tbiv	-13 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	2.36 kW	1.78 kW
COP Tj = -7°C	3.44	2.32
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	1.96 kW	1.70 kW
COP Tj = +2°C	4.80	3.54
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.34 kW	2.09 kW
COP Tj = +7°C	6.54	4.79
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.68 kW	2.43 kW
COP Tj = 12°C	8.00	6.07
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	2.99 kW	2.30 kW
COP Tj = Tbiv	2.80	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.22 kW	2.30 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.91 kW	2.82 kW
Annual energy consumption Qhe	2439 kWh	2517 kWh
Pdh Tj = -15°C (if TOL<-20°C)	2.22	2.30
COP Tj = -15°C (if TOL<-20°C)	2.17	1.72
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	51 dB(A)	53 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	185 %	130 %
Prated	4.00 kW	3.51 kW
SCOP	4.70	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.10 kW
COP Tj = -7°C	3.19	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.18 kW	2.04 kW
COP Tj = +2°C	4.50	3.26
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.32 kW	2.02 kW
COP Tj = +7°C	6.15	4.36
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.74 kW	2.44 kW
COP Tj = 12°C	8.42	5.86
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	3.54 kW	3.10 kW
COP Tj = Tbiv	3.19	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.24 kW	2.75 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.76 kW	0.76 kW
Annual energy consumption Qhe	1758 kWh	2177 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.88
Heating up time	02:06 h:min
Standby power input	80.0 W
Reference hot water temperature	50.5 °C
Mixed water at 40°C	242 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	106 %
COP	2.55
Heating up time	03:00 h:min
Standby power input	80.0 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	246 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	102 %
COP	2.45
Heating up time	02:32 h:min
Standby power input	80.0 W
Reference hot water temperature	50.7 °C
Mixed water at 40°C	246 l

Model: HA 5-5 OS 230V + HA 5-5 WSB

Configure model	
Model name	HA 5-5 OS 230V + HA 5-5 WSB
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.42 kW	3.69 kW
El input	0.95 kW	1.38 kW
COP	4.68	2.67

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	156 %
Prated	3.76 kW	3.30 kW
SCOP	6.41	3.98
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.76 kW	3.30 kW
COP Tj = +2°C	3.69	2.24
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.25 kW	2.06 kW
COP Tj = +7°C	5.81	3.36
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.70 kW	2.41 kW
COP Tj = 12°C	8.08	5.31
Cdh Tj = +12 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 14 Oct 2022

Pdh Tj = Tbiv	3.76 kW	3.30 kW
COP Tj = Tbiv	3.69	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.76 kW	3.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.69	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	783 kWh	1108 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825		
-----------------	--	--

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	158 %	110 %
Prated	5.19 kW	4.00 kW
SCOP	4.02	2.83
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	2.96 kW	2.44 kW
COP Tj = -7°C	3.41	2.42
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	1.97 kW	1.72 kW
COP Tj = +2°C	4.87	3.56
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.36 kW	2.11 kW
COP Tj = +7°C	6.57	4.89
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.68 kW	2.52 kW
COP Tj = 12°C	8.00	6.71
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	4.24 kW	3.26 kW
COP Tj = Tbiv	2.42	1.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.30 kW	3.26 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.11	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.19 kW	4.00 kW
Annual energy consumption Qhe	3182 kWh	3485 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.30	3.26
COP Tj = -15°C (if TOL<-20°C)	2.11	1.68
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	175 %	135 %
Prated	5.22 kW	5.24 kW
SCOP	4.44	3.46
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.83 kW	4.33 kW
COP Tj = -7°C	2.71	2.00
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	2.67 kW	2.57 kW
COP Tj = +2°C	4.26	3.36
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.30 kW	2.09 kW
COP Tj = +7°C	6.06	4.67
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.71 kW	2.52 kW
COP Tj = 12°C	8.39	6.41
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	4.61 kW	4.63 kW
COP Tj = Tbiv	2.64	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.90 kW	3.72 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.32 kW	1.50 kW
Annual energy consumption Qhe	2427 kWh	3129 kWh

Model: HA 5-5 OS 230V + HA 5-5 STB

Configure model	
Model name	HA 5-5 OS 230V + HA 5-5 STB
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.42 kW	3.69 kW
El input	0.95 kW	1.38 kW
COP	4.68	2.67

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	156 %
Prated	3.76 kW	3.30 kW
SCOP	6.41	3.98
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.76 kW	3.30 kW
COP Tj = +2°C	3.69	2.24
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.25 kW	2.06 kW
COP Tj = +7°C	5.81	3.36
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	2.70 kW	2.41 kW
COP Tj = 12°C	8.08	5.31
Cdh Tj = +12 °C	0.97	0.98

This information was generated by the HP KEYMARK database on 14 Oct 2022

Pdh Tj = Tbiv	3.76 kW	3.30 kW
COP Tj = Tbiv	3.69	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.76 kW	3.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.69	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	783 kWh	1108 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	158 %	110 %
Prated	5.19 kW	4.00 kW
SCOP	4.02	2.83
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	2.96 kW	2.44 kW
COP Tj = -7°C	3.41	2.42
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	1.97 kW	1.72 kW
COP Tj = +2°C	4.87	3.56
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.36 kW	2.11 kW
COP Tj = +7°C	6.57	4.89
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.68 kW	2.52 kW
COP Tj = 12°C	8.00	6.71
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	4.24 kW	3.26 kW
COP Tj = Tbiv	2.42	1.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.30 kW	3.26 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

$COP_{Tj} = TOL$ or $COP_{Tj} = T_{designh}$ if $TOL < T_{designh}$	2.11	1.68
$Cdh_{Tj} = TOL$ or $Pdh_{Tj} = T_{designh}$ if $TOL < T_{designh}$	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.19 kW	4.00 kW
Annual energy consumption Q_{he}	3182 kWh	3485 kWh
$Pdh_{Tj} = -15^{\circ}C$ (if $TOL < -20^{\circ}C$)	3.30	3.26
$COP_{Tj} = -15^{\circ}C$ (if $TOL < -20^{\circ}C$)	2.11	1.68
$Cdh_{Tj} = -15^{\circ}C$	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 14 Oct 2022

	Low temperature	Medium temperature
η_s	175 %	135 %
Prated	5.22 kW	5.24 kW
SCOP	4.44	3.46
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.83 kW	4.33 kW
COP Tj = -7°C	2.71	2.00
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	2.67 kW	2.57 kW
COP Tj = +2°C	4.26	3.36
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.30 kW	2.09 kW
COP Tj = +7°C	6.06	4.67
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.71 kW	2.52 kW
COP Tj = 12°C	8.39	6.41
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	4.61 kW	4.63 kW
COP Tj = Tbiv	2.64	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.90 kW	3.72 kW

This information was generated by the HP KEYMARK database on 14 Oct 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.32 kW	1.54 kW
Annual energy consumption Qhe	2427 kWh	3129 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.88
Heating up time	02:06 h:min
Standby power input	80.0 W
Reference hot water temperature	50.5 °C
Mixed water at 40°C	242 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	106 %
COP	2.55
Heating up time	03:00 h:min
Standby power input	80.0 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	246 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	1.02 %
COP	2.45
Heating up time	02:32 h:min
Standby power input	80.0 W
Reference hot water temperature	50.7 °C
Mixed water at 40°C	246 l